

and telephone number, date petition was mailed, plant name, and publication date and page number of this Federal Register notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to Harold F. Reis, Esquire, Newman; and Holtzinger, 1615 L Street, NW., Washington, DC 20036, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated June 1, 1996, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room, located at the Indian River Junior College Library, 3209 Virginia Avenue, Fort Pierce, Florida 34954-9003.

Dated at Rockville, Maryland, this 3rd day of June 1996.

For the Nuclear Regulatory Commission,
Leonard A. Wiens,
Senior Project Manager, Project Directorate II-3, Division of Reactor Projects—I/II, Office of Nuclear Reactor Regulation.

[FR Doc. 96-14391 Filed 6-6-96; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-244]

Exemption

In the Matter of Rochester Gas and Electric Corporation, R.E. Ginna Nuclear Power Plant)

I

On December 10, 1984, the Nuclear Regulatory Commission issued Facility Operating License No. DPR-18 to Rochester Gas and Electric Corporation (RG&E) for the R.E. Ginna Nuclear Power Plant (Ginna). The license stipulated, among other things, that the facility is subject to all rules, regulations, and orders of the Commission.

II

The *Code of Federal Regulations*, Paragraph I.D.3, "Calculation of Reflood

Rate for Pressurized Water Reactors [PWRs]," of Appendix K to Part 50 of Title 10 of the *Code of Federal Regulations* (10 CFR) requires that the refilling of the reactor vessel and the time and rate of reflooding of the core be calculated by an acceptable model that considers the thermal and hydraulic characteristics of the core and of the reactor system. In particular, Paragraph I.D.3 requires, in part, that, "The ratio of the total fluid flow at the core exit plane to the total flow at the core inlet plane (carryover fraction) shall be used to determine the core exit flow and shall be determined in accordance with applicable experimental data." The purpose of this requirement is to assure that the core exit flow during the post-loss-of-coolant accident (LOCA) refill/reflood phase is determined using a model that accounts for appropriate experimental data.

Paragraph I.D.5, "Refill and Reflood Heat Transfer for Pressurized Reactors," of Appendix K to 10 CFR Part 50 requires that for (1) reflood rates of 1 inch per second or higher, the reflood heat transfer coefficients be based on applicable experimental data for unblocked cores, and (2) reflood rates less than 1 inch per second during refill and reflood, heat transfer calculations be based on the assumption that cooling is only by steam.

License Condition 2.D provided an exemption from 10 CFR 50.46(a)(1) that the emergency core cooling system (ECCS) performance be calculated in accordance with an acceptable calculational model which conforms to the provisions of Appendix K (SER dated April 18, 1978). The exemption will expire upon receipt and approval of revised ECCS calculations.

By letter dated November 5, 1992, as supplemented on June 19, 1995, RG&E (the licensee) requested an exemption from 10 CFR Part 50, Appendix K, Paragraphs I.D.3 and I.D.5 based on revised ECCS calculations.

The November 5, 1992, exemption request was supported first by a plant specific ECCS evaluation model (EM) using a methodology not yet approved by NRC (WCAP-10924-P, Volume 2, Revision 2, Addendum 3). The proposed EM would have supported the May 1993, 1994, and 1995 core reloads. However, the WCAP-10924-P, Revision 2, Volume 2, Addendum 3 methodology has not yet been approved by NRC. On June 19, 1995, the licensee supported the November 5, 1992, exemption request by an updated plant specific EM using a methodology approved by NRC (WCAP-10924-P, Volume 1, Revision 1, Addendum 4). The proposed June 19, 1995, EM includes larger peaking factors

necessary to support conversion to an 18-month fuel-cycle reload to begin in May 1996.

The specific provision of Paragraph I.D.3 from which the licensee requested an exemption, is the calculation of core exit flow based on carryover fraction. The licensee stated that the prescriptions for this calculation given in Paragraph I.D.3 were based on data for a bottom-flooding configuration design. The Ginna design relies on upper plenum injection (UPI) for the ECCS injection during the reflood phase of a large-break LOCA. UPI is not a "lower flooding design;" its ECCS flow patterns, flow magnitudes, core cooling mechanisms, and, in fact, the meanings and impacts of the terms "inlet" and "exit" are different than those of bottom flooding plants. This EM described in WCAP 10924-P, Volume 1, Revision 2, Addendum 4, "Westinghouse UPI Model Improvements," dated August 1990, which has been generically approved in a staff SER of February 8, 1991, determines core flow, including flow "exiting" the core, flow "entering" the core, and flow within the core and elsewhere within the reactor coolant system (RCS) in accordance with applicable experimental data. The data are different than that referenced in paragraph I.D.3, however, they were found acceptable because they are specifically applicable to UPI designs. Because of the differences between UPI design considerations and those for bottom flooding designs mentioned above, the "carryover fraction" as defined in paragraph I.D.3 is not calculated in the approved EM and would not have the same technical significance if it were. The licensee, therefore, concludes that, in using the approved UPI model with its technical improvements for Ginna, it will not comply with Paragraph I.D.3. The staff SER of February 8, 1991, finds WCAP-10924-P EM contains an empirically verified model more directly applicable to top flooding situations to calculate core exit flow, which satisfies the technical purpose of this Appendix K, paragraph I.D.3 requirement to determine the core exit flow, but does not comply with the letter of the requirement.

In more detail, the intent of the Appendix K, paragraph I.D.3, is to assure that the calculation of core exit flow is performed using an EM code model which has been verified against appropriate experimental data for LOCA accident analyses. The Westinghouse COBRA/TRAC code (WCOBRA/TRAC) consists of (1) Westinghouse Large-Break LOCA Best Estimate Methodology, Volume 1: Model

Description and Validation, WCAP-10924-P, April 1986, and (2) a Westinghouse Large-Break LOCA Best Estimate Methodology, Volume 2: Application to Two-Loop PWRs Equipped with Upper Plenum Injection, WCAP-10924, Volume 2, Revision 1, April 1988.

To assess WCOBRA/TRAC's capability for predicting the correct thermal-hydraulic behavior for upper plenum injection situations, WCOBRA/TRAC has been compared to the Japanese Cylindrical Core Test Facility data which models the interaction effects of upper plenum injection in a large scale test facility. WCOBRA/TRAC predicts the thermal-hydraulic effects of the upper plenum injection such that the carryover of steam and water into the hot legs is more realistically calculated.

The staff finds that the exemption from Paragraph I.D.3 requirement is acceptable because the licensee has provided an acceptable method to satisfy the underlying purpose of the requirement that appropriately models heat transfer mechanisms in UPI designs and application of the regulation is not necessary to achieve the underlying purpose of the rule.

Paragraph I.D.5, dealing with refill and reflood heat transfer for PWRs, provides heat transfer prescriptions for refill, reflood with a flooding rate of less than 1 inch per second, and reflood with a flooding rate of more than 1 inch per second for bottom-flooding PWRs. The purpose of the paragraph is to assure that heat transfer in the core is appropriately calculated in the refill and reflood phases of post-LOCA recovery.

Paragraph I.D.5.a requires that "New correlations or modifications to the FLECHT heat transfer correlations are acceptable only after they are demonstrated to be conservative, by comparison with FLECHT data, for a range of parameters consistent with the transient to which they are applied." The licensee requested an exemption from the prescriptions of this paragraph because the FLECHT data do not portray UPI core heat transfer mechanisms as realistically as the more recent data upon which the models in WCAP-10924 were based. The licensee also indicates that the Ginna design is not lower flooding, and that technical considerations are different between bottom flooding designs and UPI design similar to those discussed above for paragraph I.D.3. The licensee identified that the WCAP-10924-P EM contains an empirically verified model which accounts for refill and reflood heat transfer, which satisfies the purpose of the paragraph I.D.5.a requirement. The

heat transfer models in the approved UPI EM are based on comparisons to data other than the FLECHT data cited in Paragraph I.D.5.a, and comparisons to the applicable data demonstrate acceptable conservatism (as identified in the staff SER of February 8, 1991). Because of the differences in bases, it is not clear that the licensee can demonstrate monotonic conservatism with respect to FLECHT data.

Further, to meet the intent of Appendix K, paragraph I.D.5, which is to use the most applicable data for LOCA accident analyses to appropriately calculate heat transfer during the refill and reflood phases; the WCOBRA/TRAC code has been verified against two independent sets of experimental data which model the upper plenum injection flow and heat transfer situation.

The first series of tests which have been modeled by WCOBRA/TRAC are the Westinghouse G-2 refill downflow and counterflow rod bundle film boiling experiments (Westinghouse G-2, 17x17 Refill Heat Transfer Tests and Analysis, WCAP-8793, August 1976).

These experiments were performed as a full length 17x17 Westinghouse rod bundle array which had a total of 336 heated rods. The injection flow was from the top of the bundle and is scalable to the UPI injection flows. The pressures varied between 20-100 psia which is the typical range for UPI top flooding situations. Both concurrent downflow film boiling and countercurrent film boiling experiments were modeled using WCOBRA/TRAC. Both these flow situations are found in the calculated core response for a PWR with UPI.

In addition to modeling these separate effects tests, WCOBRA/TRAC has been used to model the Japanese Cylindrical Core Test Facility experiments with upper plenum injection. The tests which have been modeled included: (1) A symmetrical UPI injection with maximum injection flow, (2) minimum injection flows with a nearly symmetrical injection pattern, (3) a minimum UPI injection flow with a skewed UPI injection, and (4) a cold leg injection reference test for the UPI tests.

The results of these comparisons are documented and show that WCOBRA/TRAC does predict heat transfer behavior for these complex film boiling situations as well as the system response for upper plenum injection situations.

The effect of flow blockage due to cladding burst is explicitly accounted for in WCOBRA/TRAC with models which calculate cladding swelling, burst, and area reduction due to

blockage. These models are based on previously approved models used in current evaluation models and on flow blockage models determined to be acceptable by the staff. The effect of flow blockage is accounted for from the time burst is calculated to occur. The fluid models in WCAP/TRAC calculate flow diversion as a result of the blockage and take into account of the blockage from the time the cladding burst is calculated to occur. Thus, the heat transfer behavior is predicted for these complex film boiling situations and, thus, the intent of Appendix K, paragraph I.D.5, which requires flow blockage effects be taken into account, is met.

The staff finds that the exemption from the paragraph I.D.5.a requirement is acceptable based on the provision of an acceptable method to satisfy the purpose of the paragraph and the application of the regulation to calculate core reflood rates and heat transfer during a LB LOCA.

Paragraph I.D.5.b requires that "During refill and during reflood when reflood rates are less than one inch per second, heat transfer calculations shall be based on the assumption that cooling is only by steam, and shall take into account any flow blockage calculated to occur as a result of cladding swelling or rupture as such blockage might affect both local steam flow and heat transfer." The EM approved for UPI plants which the licensee proposes to reference does base heat transfer on cooling other than steam if other regimes are calculated to occur. The bases of acceptability, including data comparisons, for this are discussed in the generic SER for the EM. By using this methodology, the licensee does not comply with this requirement, since the methodology recognizes that for a top flooding design, the preponderance of cooling water falls down into the core from above and may or may not be vaporized. Because the licensee's model does not meet the "steam cooling only" requirement of I.D.5.b, but provides an approved alternate methodology (which does consider the thermal and hydraulic effects of cladding swelling and rupture, as also required in paragraph I.D.5.b) for calculating heat transfer, the staff finds the exemption from the requirement of I.D.5.b acceptable, as compliance is demonstrated not to be necessary to achieve the underlying purpose of the rule.

III

Section 50.12 of 10 CFR permits the granting of an exemption from the regulations under special circumstances. According to 10 CFR

50.12(a)(2)(ii), special circumstances are present whenever application of the regulation in question is not necessary to achieve the underlying purpose of the rule.

The staff finds that the requested exemptions for Ginna are acceptable, since compliance with the literal requirements of the paragraphs cited is not necessary given that the approved EM is based upon appropriate experimental data, the approved EM satisfactorily accounts for the cooling mechanisms in the Ginna UPI design for calculations of core reflood rates and heat transfer during a LB LOCA, and that the approved EM satisfies the purpose of the exempted requirements.

Thus, using the best-estimate thermal-hydraulic approved LBLOCA EM, the underlying purpose of the Appendix K, paragraphs I.D.3 and I.D.5 requirements can be achieved.

IV

Accordingly, the Commission has determined that, pursuant to 10 CFR 50.12, this exemption is authorized by law, will not present an undue risk to the public health and safety, and is consistent with the common defense and security.

Accordingly, the Commission hereby grants an exemption from 10 CFR Part 50, Appendix K, paragraphs I.D.3 and I.D.5. The staff also finds that the LB LOCA EM described in any approved version of WCAP-10924-P incorporated in the Ginna Technical Specifications may be used in core operating report, and licensing analyses, and that further exemptions will not be necessary unless the updated approved versions of the EM do not meet other requirements of 10 CFR 50.46 and/or Appendix K.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of the exemption will have no significant impact on the quality of the human environment (61 FR 13891).

This exemption is effective upon issuance.

For the Nuclear Regulatory Commission.

Dated at Rockville, Maryland, this 31st day of May 1996.

Steven A. Varga,

Director, Division of Reactor Projects—I/II
Office of Nuclear Reactor Regulation.

[FR Doc. 96-14395 Filed 6-6-96; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR WASTE TECHNICAL REVIEW BOARD

Board Meeting: Exploration and Testing Activities, Past and Future Climates and Hydrology at Yucca Mountain

Pursuant to its authority under section 5051 of Public Law 100-203, the Nuclear Waste Policy Amendments Act of 1987, the Nuclear Waste Technical Review Board will hold its summer meeting on Tuesday and Wednesday, July 9-10, 1996, in Denver, Colorado. The meeting will be held at the Red Lion Hotel, 3203 Quebec Street, Denver, CO 80207; (tel) 303-321-3333; (fax) 303-329-9179. To receive the preferred rate, reservations must be made by June 16, 1996; please tell the hotel you are attending the Nuclear Waste Technical Review Board meeting. The meeting is open to the public and will begin at 8:30 A.M. both days.

The Board will explore two basic themes during the meeting: activities in the Yucca Mountain exploratory studies facility (ESF), and past and future climates and their associated effects on the hydrology at Yucca Mountain. The Board has invited representatives of the Office of Civilian Radioactive Waste Management (OCRWM) and its contractors, as well as independent consultants, to make presentations on the issues. Specific topics concerning the ESF will include updates on tunnel boring machine operations and scientific activities, the status of the waste isolation strategy, thermal testing, and advanced conceptual design for the repository. Presentations on climate and its effects on hydrology will include the geological structure at Yucca Mountain, historical perspectives and current views on both climate and hydrology, and climate modeling. Time has been set aside on the second day for a round-table discussion of all topics covered by the meeting.

Time also has been set aside for public comment and questions on both days. To ensure that everyone wishing to speak is provided time to do so, the Board encourages those who have comments to sign the *Public Comment Register*, which will be located at the sign-in table. Depending on the number of people wishing to speak, a time limit may have to be set on the length of individual remarks. However, written comments of any length may be submitted for the record.

The Nuclear Waste Technical Review Board was created by Congress in the Nuclear Waste Policy Amendments Act of 1987 to evaluate the technical and scientific validity of activities

undertaken by the DOE in its program to manage the disposal of the nation's spent nuclear fuel and defense high-level waste. In that same legislation, Congress directed the DOE to characterize a site at Yucca Mountain, Nevada, for its suitability as a potential location for a permanent repository for the disposal of that waste.

Transcripts of this meeting will be available via e-mail, on computer disk, or on a library-loan basis in paper format from Davonya Barnes, Board staff, beginning August 21, 1996. For further information, contact Frank Randall, External Affairs, 1100 Wilson Boulevard, Suite 910, Arlington, Virginia 22209; (Tel) 703-235-4473; (Fax) 703-235-4495.

Dated: June 4, 1996.

William Barnard,

Executive Director, Nuclear Waste Technical Review Board.

[FR Doc. 96-14375 Filed 6-6-96; 8:45 am]

BILLING CODE 6820-AM-M

RAILROAD RETIREMENT BOARD

Agency Forms Submitted for OMB Review

SUMMARY: In accordance with the Paperwork Reduction Act of 1995 (44 U.S.C. Chapter 35), the Railroad Retirement Board has submitted the following proposal(s) for the collection of information to the Office of Management and Budget for review and approval.

Summary of Proposal(s)

- (1) *Collection title:* Application for Survivor Insurance Annuities.
- (2) *Form(s) submitted:* AA-17, AA-17b, AA-18, AA-19, AA-19a, and AA-20.
- (3) *OMB Number:* 3220-0030.
- (4) *Expiration date of current OMB clearance:* June 30, 1996.
- (5) *Type of request:* Revision of a currently approved collection.
- (6) *Respondents:* Individuals or households.
- (7) *Estimated annual number of respondents:* 5,765.
- (8) *Total annual responses:* 5,765.
- (9) *Total annual reporting hours:* 2,864.
- (10) *Collection description:* Under Section 2(d) of the RRA, monthly survivor annuities are payable to surviving widow(er)s, parents, unmarried children, and in certain cases, divorced wives (husbands), mother (fathers), remarried widow(er)s and grandchildren or deceased railroad employees. The collection obtains information needed by the Railroad