

the reactor coolant pressure boundary as set forth in Appendices G and H to 10 CFR Part 50. Appendix G to 10 CFR Part 50 defines pressure/temperature (P/T) limits during any condition of normal operation, including anticipated operational occurrences and system hydrostatic tests to which the pressure boundary may be subjected over its service lifetime. It is specified in 10 CFR 50.60(b) that alternatives to the described requirements in Appendices G and H to 10 CFR Part 50 may be used when an exemption is granted by the Commission under 10 CFR 50.12.

The licensee relies on the electromagnetic relief valve (ERV) to provide low temperature overpressure protection (LTOP). The ERV is mounted on the pressurizer and helps to control pressure transients during power operations. However, when the reactor is heating up or cooling down and the primary system pressure and temperature are reduced, the ERV is reset to the LTOP mode. In the LTOP mode the setpoint to open the ERV is low enough to prevent pressure transients from exceeding applicable P/T limits. Some margin should be maintained between the primary system pressure and the LTOP setpoint to prevent the ERV from lifting as a result of normal operating pressure surges.

The licensee has requested the use of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (Code) Case N-514, "Low Temperature Overpressure Protection," which allows exceeding the Appendix G safety limits by 10 percent. ASME Code Case N-514, the proposed alternate methodology, is consistent with guidelines developed by the ASME Working Group on Operating Plant Criteria to define pressure limits during LTOP events that avoid certain unnecessary operational restrictions, provide adequate margins against failure of the reactor pressure vessel, and reduce the potential for unnecessary activation of pressure-relieving devices used for LTOP. Code Case N-514 has been approved by the ASME Code Committee. The content of this code case has been incorporated into Appendix G of Section XI of the ASME Code and published in the 1993 Addenda to Section XI.

III

Pursuant to 10 CFR 50.12, the Commission may, upon application by any interested person or upon its own initiative, grant exemptions from the requirements of 10 CFR Part 50 (1) when the exemptions are authorized by law, will not present an undue risk to public health or safety, and are consistent with

the common defense and security; and (2) when special circumstances are present. Special circumstances are present whenever, according to 10 CFR 50.12(a)(2)(ii), "Application of the regulation in the particular circumstances would not serve the underlying purpose of the rule or is not necessary to achieve the underlying purpose of the rule. * * *

The underlying purpose of 10 CFR 50.60, Appendix G, is to establish fracture toughness requirements for ferritic materials of pressure-retaining components of the reactor coolant pressure boundary to provide adequate margins of safety during any condition of normal operation, including anticipated operational occurrences, to which the pressure boundary may be subjected over its service lifetime. Section IV.A.2 of this appendix requires that the reactor vessel be operated with P/T limits at least as conservative as those obtained by following the methods of analysis and the required margins of safety of Appendix G of the ASME Code.

Appendix G of the ASME Code requires that the P/T limits be calculated: (a) Using a safety factor of two on the principal membrane (pressure) stresses, (b) assuming a flaw at the surface with a depth of one-quarter (1/4) of the vessel wall thickness and a length of six (6) times its depth, and (c) using a conservative fracture toughness curve that is based on the lower bound of static, dynamic, and crack arrest fracture toughness tests on material similar to the ANO-1 reactor vessel material.

In determining the setpoint for LTOP events, the licensee proposed to use safety margins based on an alternate methodology consistent with the ASME Code Case N-514 guidelines. The ASME Code Case N-514 allows determination of the setpoint for LTOP events such that the maximum pressure in the vessel would not exceed 110 percent of the P/T limits of the existing ASME Appendix G. This results in a safety factor of 1.8 on the principal membrane stresses. All other factors, including assumed flaw size and fracture toughness, remain the same. Although this methodology would reduce the safety factor on the principal membrane stresses, the proposed criteria will provide adequate margins of safety to the reactor vessel during LTOP transients and, thus, will satisfy the underlying purpose of 10 CFR 50.60 for fracture toughness requirements. Further, by relieving the operational restrictions, the potential for undesirable lifting of the ERV would be reduced, thereby improving plant safety.

IV

For the foregoing reasons, the NRC staff has concluded that the licensee's proposed use of the alternate methodology in determining the acceptable setpoint for LTOP events will not present an undue risk to public health and safety and is consistent with the common defense and security. The NRC staff has determined that there are special circumstances present, as specified in 10 CFR 50.12(a)(2), in that application of 10 CFR 50.60 is not necessary in order to achieve the underlying purpose of this regulation.

Accordingly, the Commission has determined that, pursuant to 10 CFR 50.12(a), an exemption is authorized by law, will not endanger life or property or common defense and security, and is, otherwise, in the public interest. Therefore, the Commission hereby grants an exemption from the requirements of 10 CFR 50.60 such that in determining the setpoint for LTOP events, the Appendix G curves for P/T limits are not exceeded by more than 10 percent in order to be in compliance with these regulations. This exemption is applicable only to LTOP conditions during normal operation.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will not have a significant effect on the quality of the human environment (62 FR 11482).

This exemption is effective upon issuance.

Dated at Rockville, Maryland, this 12th day of March 1997.

For the Nuclear Regulatory Commission.
Samuel J. Collins,
Director, Office of Nuclear Reactor Regulation.

[FR Doc. 97-6756 Filed 3-17-97; 8:45 am]

BILLING CODE 7590-01-P

[Docket No. 50-388]

Susquehanna Steam Electric Station, Unit 2; Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-22, issued to Pennsylvania Power & Light Company (the licensee), for operation of the

Susquehanna Steam Electric Station, Unit 2, located in Luzerne County, PA.

The proposed amendment would make the following changes to the Technical Specifications for the plant to reflect the initiation of a 24-month fuel

cycle and the use of the Atrium-10 fuel design: (1) Inclusion of core flow dependent minimum critical power ratio (MCPR) Safety Limits in Sections 2.1.2 and 3.4.1.1.2, (2) inclusion of Siemens Power Corporation (SPC) methodology topical reports in Section 6.9.3.2, changes to Section 5.3.1 to reflect new fuel design features, and (3) changes to definitions in Section 1 to reflect the new fuel design.

A notice of consideration of issuance of amendment with a proposed no significant hazards consideration determination was published in the Federal Register on January 15, 1997 (62 FR 2193). This notice supersedes the January 15, 1997, notice.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By April 17, 1997, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, PA 18701. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) The nature of the

petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Docketing and Services Branch, or may

be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. Where petitions are filed during the last 10 days of the notice period, it is requested that the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-(800) 248-5100 (in Missouri 1-(800) 342-6700). The Western Union operator should be given Datagram Identification Number N1023 and the following message addressed to John F. Stolz, Director, Project Directorate I-2: petitioner's name and telephone number; date petition was mailed; plant name; and publication date and page number of this Federal Register notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to Jay Silberg, Esquire, Shaw, Pittman, Potts and Trowbridge, 2300 N Street NW., Washington, DC 20037, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for a hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendment dated December 18, 1996, as supplemented March 12, 1997, which are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, PA 18701.

Dated at Rockville, Maryland, this 12th day of March 1997.

For the Nuclear Regulatory Commission,
Donald S. Brinkman,
*Acting Director, Project Directorate I-2,
Division of Reactor Projects—I/II, Office of
Nuclear Reactor Regulation.*

[FR Doc. 97-6757 Filed 3-17-97; 8:45 am]

BILLING CODE 7590-01-P