

a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee's letter dated January 17, 1997, which is available for public inspection at the Commission's Public Document Room, The Gelman Building, 2120 L Street, NW., Washington, DC and at the local public document rooms located at the Salem Free Public Library, 112 West Broadway, Salem, New Jersey, for Salem and at the Pennsville Public Library, 190 S. Broadway, Pennsville, New Jersey, for Hope Creek.

Dated at Rockville, Maryland, this 23rd day of July 1997.

For the Nuclear Regulatory Commission.

John F. Stolz,

Director Project Directorate, I-2, Division of Reactor Projects—I/II, Office of Nuclear Reactor Regulation.

[FR Doc. 97-19932 Filed 7-28-97; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-413 and 50-414]

Duke Power Company, et al.; Catawba Nuclear Station, Units 1 and 2; Environmental Assessment and Finding of No Significant Impact

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an exemption from certain requirements of its regulations to Facility Operating License Nos. NPF-35 and NPF-52, issued to Duke Power Company, et al. (the licensee), for operation of the Catawba Nuclear Station, Units 1 and 2, located in York County, South Carolina.

Environmental Assessment

Identification of Proposed Action

The proposed action would exempt the licensee from the requirements of 10 CFR 70.24, which requires a monitoring system that will energize clear audible alarms if accidental criticality occurs in each area in which special nuclear material is handled, used, or stored. The proposed action would also exempt the licensee from the requirements to maintain emergency procedures for each area in which this licensed special nuclear material is handled, used, or stored to ensure that all personnel withdraw to an area of safety upon the sounding of the alarm, to familiarize personnel with the evacuation plan, and to designate responsible individuals for

determining the cause of the alarm, and to place radiation survey instruments in accessible locations for use in such an emergency.

The proposed action is in response to the licensee's application dated February 4, 1997, as supplemented by letter on March 19, 1997.

The Need for the Proposed Action

The purpose of 10 CFR 70.24 is to ensure that if a criticality were to occur during the handling of special nuclear material, personnel would be alerted to that fact and would take appropriate action. At a commercial nuclear power plant the inadvertent criticality with which 10 CFR 70.24 is concerned could occur during fuel handling operations. The special nuclear material that could be assembled into a critical mass at a commercial nuclear power plant is in the form of nuclear fuel; the quantity of other forms of special nuclear material that is stored on site is small enough to preclude achieving a critical mass. Because the fuel is not enriched beyond 5.0 weight percent Uranium-235 and because commercial nuclear plant licensees have procedures and features designed to prevent inadvertent criticality, the staff has determined that it is unlikely that an inadvertent criticality could occur due to the handling of special nuclear material at a commercial power reactor. The requirements of 10 CFR 70.24, therefore, are not necessary to ensure the safety of personnel during the handling of special nuclear materials at commercial power reactors.

Environmental Impacts of the Proposed Action

The Commission has completed its evaluation of the proposed action and concludes that there is no significant environmental impact if the exemption is granted. Inadvertent or accidental criticality will be precluded through compliance with the Catawba Nuclear Station Technical Specifications, the design of the fuel storage racks providing geometric spacing of fuel assemblies in their storage locations, and administrative controls imposed on fuel handling procedures. Technical Specifications requirements specify reactivity limits for the fuel storage racks and minimum spacing between the fuel assemblies in the storage racks.

Appendix A of 10 CFR part 50, "General Design Criteria for Nuclear Power Plants," Criterion 62, requires the criticality in the fuel storage and handling system to be prevented by physical systems or processes, preferably by use of geometrically safe configurations. This is met at Catawba,

as identified in the Technical Specification Section 3.9 and in the Updated Final Safety Analysis Report (UFSAR) Section 9.1, by detailed procedures that must be available for use by refueling personnel. Therefore, as stated in the Technical Specifications, these procedures, the Technical Specifications requirements, and the design of the fuel handling equipment with built-in interlocks and safety features, provide assurance that no incident could occur during refueling operations that would result in a hazard to public health and safety. In addition, the design of the facility does not include provisions for storage of fuel in a dry location.

UFSAR Section 9.1.1, New Fuel Storage, states that new fuel will normally be stored in the spent fuel pool serving the respective unit and that it may also be stored in the fuel transfer canal. The fuel assemblies are stored in five racks in a row having a nominal center-to-center distance of 2 feet 1¾ inches. New fuel may also be stored in shipping containers. (Note that in none of these locations would criticality be possible.)

The proposed exemption would not result in any significant radiological impacts. The proposed exemption would not affect radiological plant effluents nor cause any significant occupational exposures since the Technical Specifications, design controls (including geometric spacing and design of fuel assembly storage spaces) and administrative controls preclude inadvertent criticality. The amount of radioactive waste would not be changed by the proposed exemption.

The proposed exemption does not result in any significant nonradiological environmental impacts. The proposed exemption involves features located entirely within the restricted area as defined in 10 CFR part 20. It does not affect nonradiological plant effluents and has no other environmental impact. Accordingly, the Commission concludes that there are no significant nonradiological environmental impacts associated with the proposed action.

Alternatives to the Proposed Action

Since the Commission has concluded there is no measurable environmental impact associated with the proposed action, any alternatives with equal or greater environmental impact need not be evaluated. As an alternative to the proposed exemption, the staff considered denial of the requested exemption. Denial of the exemption would result in no change in current environmental impacts. The environmental impacts of the proposed

action and this alternative action are similar.

Alternative Use of Resources

This exemption does not involve the use of any resources not previously considered in the Final Environmental Statement related to the Catawba Nuclear Station.

Agencies and Persons Contacted

In accordance with its stated policy, on July 7, 1997, the staff consulted with the South Carolina State official, Virgil Autrey of the Bureau of Radiological Health, South Carolina Department of Health and Environmental Control, regarding the environmental impact of the proposed exemption. The State official had no comments.

Finding of No Significant Impact

Based upon the foregoing environmental assessment, the Commission concludes that the proposed exemption will not have a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed exemption.

For further details with respect to the proposed action, see the licensee's request for the exemption dated February 4, 1997, as supplemented by letter dated March 19, 1997, which are available for public inspection at the Commission's Public Document Room, The Gelman Building, 2120 L Street, NW., Washington DC, and at the local public document room located at the York County Library, 138 East Black Street, Rock Hill, South Carolina.

Dated at Rockville, Maryland, this 22nd day of July 1997.

For the Nuclear Regulatory Commission.

Herbert N. Kerkow,

Director, Project Directorate II-2, Division of Reactor Projects—I/II, Office of Nuclear Reactor Regulation.

[FR Doc. 97-19933 Filed 7-28-97; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-244]

Rochester Gas and Electric Corporation; R. E. Ginna Nuclear Power Plant; Environmental Assessment and Finding of No Significant Impact

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an exemption from certain requirements of its regulations for Facility Operating

License No. DRP-18 issued to Rochester Gas and Electric Corporation (the licensee), for operation of the R. E. Ginna Nuclear Power Plant located in Wayne County, New York.

Environmental Assessment

Identification of Proposed Action

The proposed action would allow the licensee to utilize the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code) Case N-514, "Low Temperature Overpressure Protection" to determine its low temperature overpressure protection (LTOP) setpoints and is in accordance with the licensee's application for exemption dated June 12, 1997. The proposed action requests an exemption from certain requirements of 10 CFR 50.60, "Acceptance Criteria for Fracture Prevention Measures for Lightwater Nuclear Power Reactors for Normal Operation," to allow application of an alternate methodology to determine the LTOP setpoints for the R. E. Ginna Nuclear Power Plant. The proposed alternate methodology is consistent with guidelines developed by the ASME Working Group on Operating Plant Criteria (WGOPC) to define pressure limits during LTOP events that avoid certain unnecessary operational restrictions, provide adequate margins against failure of the reactor pressure vessel, and reduce the potential for unnecessary activation of pressure relieving devices used for LTOP. These guidelines have been incorporated into Code Case N-514, "Low Temperature Overpressure Protection," which has been incorporated into Appendix G of Section XI of the ASME Code and published in the 1993 Addenda to Section XI. However, 10 CFR 50.55a, "Codes and Standards," and Regulatory Guide 1.147, "Inservice Inspection Code Case Acceptability" have not been updated to reflect the acceptability of Code Case N-514.

The philosophy used to develop Code Case N-514 guidelines is to ensure that the LTOP limits are still below the pressure/temperature (P/T) limits for normal operation, but allow the pressure that may occur with activation of pressure relieving devices to exceed the P/T limits, provided acceptable margins are maintained during these events. This philosophy protects the pressure vessel from LTOP events, and still maintains the Technical Specifications P/T limits applicable for normal heatup and cooldown in accordance with 10 CFR part 50, Appendix G and Sections III and XI of the ASME Code.

The Need for the Proposed Action

Pursuant to 10 CFR 50.60, all lightwater nuclear power reactors must meet the fracture toughness requirements for the reactor coolant pressure boundary as set forth in 10 CFR part 50, Appendix G. Appendix G of 10 CFR part 50 defines P/T limits during any condition of normal operation including anticipated operational occurrences and system hydrostatic tests, to which the pressure boundary may be subjected over its service lifetime. It is specified in 10 CFR 50.60(b) that alternatives to the described requirements in 10 CFR part 50, Appendix G, may be used when an exemption is granted by the Commission under 10 CFR 50.12.

To prevent transients that would produce excursions exceeding the 10 CFR part 50, Appendix G, P/T limits while the reactor is operating at low temperatures, the licensee installed an LTOP system. The LTOP system includes pressure relieving devices in the form of power-operated relief valves (PORVs) that are set at a pressure below the LTOP enabling temperature that would prevent the pressure in the reactor vessel from exceeding the P/T limits of 10 CFR Part 50, Appendix G. To prevent these valves from lifting as a result of normal operating pressure surges (e.g., reactor coolant pump (RCP) starting and shifting operating charging pumps) with the reactor coolant system in a solid water condition, the operating pressure must be maintained below the PORV setpoint.

In addition, to prevent damage to RCP seals, the operator must maintain a minimum differential pressure across the RCP seals. Hence, the licensee must operate the plant in a pressure window that is defined as the difference between the minimum required pressure to start a RCP and the operating margin to prevent lifting of the PORVs due to normal operating pressure surges. 10 CFR part 50, Appendix G, safety margin adds instrument uncertainty in the LTOP setpoint. The licensee's current LTOP analysis indicates that using this 10 CFR part 50, Appendix G, safety margin to determine the PORV setpoint would result in an operating window between the LTOP setpoint and the minimum pressure required for RCP seals which is significantly restricted when physical conditions such as PORV overshoot, RCP Δ Ps, and static head corrections are taken into account in setpoint determination. Operating with these limits could result in the lifting of the PORVs or damage to the RCP seals during normal operation. Using Code Case N-514 would allow the licensee to