

By letter dated February 22, 1994, the NRC approved the use of the master curve approach for the Zion Nuclear Power Station, Units 1 and 2, and the RT_{NDT} value is -26°F for WF-70 weld metal. The exemption approval for the Zion station also stated that other procedures for determination of RT_{NDT} may serve as acceptable alternatives to NB-2331 contingent on staff review and approval. The staff acceptance of the alternative procedure in that evaluation was based, in part, on the analysis of a significant amount of fracture toughness data for the WF-70 weld metal. Therefore, since TMI-1 used the same weld metal as Zion and the data considered for the Zion exemption resulted in a more representative RT_{NDT} value, the TMI-1 use of the master curve approach for WF-70 weld metal is acceptable.

In summary, the underlying purpose of 10 CFR 50.61 is to ensure that the RPV is adequately protected from PTS. Application of the master curve approach to determine the unirradiated RT_{NDT} value for weld metal WF-70 is acceptable because the master curve approach is more appropriate for material with low upper-shelf behavior like WF-70 weld metal.

Therefore, pursuant to 10 CFR 50.12(a)(2)(ii), application of the master curve approach to determine the unirradiated RT_{NDT} value for weld metal WF-70 would continue to achieve the underlying purpose of the rule, and application of the definition of $RT_{NDT(U)}$ in 10 CFR 50.61(a)(5) in these circumstances is not necessary to achieve that purpose.

4.0 Conclusion

Accordingly, the Commission has determined that, pursuant to 10 CFR 50.12(a), the exemptions are authorized by law, will not endanger life or property or common defense and security, and are, otherwise, in the public interest. Also, special circumstances are present. Therefore, the Commission hereby grants AmerGen Energy Company, LLC exemptions from the requirements of 10 CFR part 50, Appendix G, and 10 CFR part 50, § 50.61(a)(5), for TMI-1.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will not have a significant effect on the quality of the human environment (66 FR 45874).

This exemption is effective upon issuance.

Dated at Rockville, Maryland, this 30th day of August 2001.

For the Nuclear Regulatory Commission.

John A. Zwolinski,

Director, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 01-22514 Filed 9-6-01; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 72-8]

Calvert Cliffs Nuclear Power Plant; Notice of Docketing of the Materials License SNM-2505; Amendment Application for the Calvert Cliffs Independent Spent Fuel Storage Installation

By letter dated July 26, 2001, Calvert Cliffs Nuclear Power Plant, Inc. (CCNPP), submitted an application to the Nuclear Regulatory Commission (NRC or the Commission) in accordance with 10 CFR part 72 requesting an amendment of the Calvert Cliffs independent spent fuel storage installation (ISFSI) license (SNM-2505) for the ISFSI located in Calvert County, Maryland. CCNPP is requesting Commission approval to amend SNM-2505 to reflect revised fuel assembly integrity analysis as described in the Safety Analysis Report. CCNPP proposed changes to Technical Specification 2.3 to remove the 15-inch drop height limit and require inspection after any drop of a dry shielded canister. CCNPP also proposed a change to Technical Specification 6.3 to revise the reference to a semi-annual environmental reporting period to be consistent with the annual reporting requirements of 10 CFR 50.36a(2).

This application was docketed under 10 CFR part 72; the ISFSI Docket No. is 72-8 and will remain the same for this action. The amendment of an ISFSI license is subject to the Commission's approval.

The Commission may issue either a notice of hearing or a notice of proposed action and opportunity for hearing in accordance with 10 CFR 72.46(b)(1) or, if a determination is made that the amendment does not present a genuine issue as to whether public health and safety will be significantly affected, take immediate action on the amendment in accordance with 10 CFR 72.46(b)(2) and provide notice of the action taken and an opportunity for interested persons to request a hearing on whether the action should be rescinded or modified.

The NRC maintains an Agencywide Documents Access and Management System (ADAMS), which provides text and image files of NRC's public

documents. These documents may be accessed through NRC's Public Electronic Reading Room on the Internet at <http://www.nrc.gov/nrc/adams/index.html>. If you do not have access to ADAMS or if there are problems in accessing documents located in ADAMS, contact the NRC Public Document Room Reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 29th day of August 2001.

For the Nuclear Regulatory Commission.

E. William Brach,

Director, Spent Fuel Project Office, Office of Nuclear Material Safety and Safeguards.

[FR Doc. 01-22515 Filed 9-6-01; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-334 and 50-412]

FirstEnergy Nuclear Operating Company, et al., Beaver Valley Power Station, Unit Nos. 1 and 2; Notice of Issuance of Amendment to Facility Operating License

The U.S. Nuclear Regulatory Commission (Commission) has issued Amendment Nos. 241 and 121 to Facility Operating License Nos. DPR-66 and NPF-73, respectively, issued to FirstEnergy Nuclear Operating Company, et al. (the licensee), which revised the Technical Specifications (TSs) and authorized revisions to the Updated Final Safety Analysis Report (UFSAR) for operation of Beaver Valley Power Station, Unit Nos. 1 and 2, located in Shippingport, Pennsylvania. The amendment is effective as of the date of issuance.

The amendment authorized revisions to the BVPS-1 and 2 UFSAR design-basis fuel handling accident (FHA) dose consequence analyses. The amendment also revised the BVPS-1 and 2 TSs associated with the requirements for handling irradiated fuel assemblies in the reactor containment and fuel building and the TS requirements associated with ensuring that UFSAR safety analysis assumptions are met for a postulated FHA. The term "recently irradiated" fuel is defined in the applicable TS Bases as "fuel that has occupied part of a critical reactor core within the previous 100 hours." The purpose of the addition of the term "recently irradiated" throughout the TSs is to establish a point where operability of those systems typically used to mitigate the consequences of an FHA is no longer required to meet the

radiation exposure limits of 10 CFR 50.67. This amendment revises the TSs to eliminate TS controls over the integrity of the fuel building and the reactor containment building and the operability of the associated building's ventilation/filtration systems after the decay period of 100 hours.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for a Hearing in connection with this action was published in the **Federal Register** on June 4, 2001 (66 FR 30026). No request for a hearing or petition for leave to intervene was filed following this notice.

The Commission has prepared an Environmental Assessment related to the action and has determined not to prepare an environmental impact statement. Based upon the environmental assessment, the Commission has concluded that the issuance of the amendment will not have a significant effect on the quality of the human environment.

For further details with respect to the action see (1) the application for amendment dated March 19, 2001 (Agencywide Documents Access and Management System [ADAMS] Accession No. ML010810433), as supplemented by letters dated July 6 (ADAMS Accession No. ML011980423), August 8 (ADAMS Accession No. ML012260302), and August 23, 2001 (ADAMS Accession No. ML012420089), (2) Amendment Nos. 241 and 121 to License Nos. DPR-66 and NPF-73, (3) the Commission's related Safety Evaluation, and (4) the Commission's Environmental Assessment, dated August 17, 2001 (ADAMS Accession No. ML012210436). Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the ADAMS Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/NRC/ADAMS/index.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS should contact the NRC PDR Reference staff by telephone

at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr@nrc.gov.

Dated at Rockville, Maryland, this 30th day of August 2001.

For the Nuclear Regulatory Commission.

Lawrence J. Burkhardt,

Project Manager, Section 1, Project Directorate I, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 01-22517 Filed 9-6-01; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Draft Regulatory Guide; Issuance, Availability

The Nuclear Regulatory Commission has issued for public comment a proposed revision of a guide in its Regulatory Guide Series. This series has been developed to describe and make available to the public such information as methods acceptable to the NRC staff for implementing specific parts of the NRC's regulations, techniques used by the staff in evaluating specific problems or postulated accidents, and data needed by the staff in its review of applications for permits and licenses.

The draft guide, temporarily identified by its task number, DG-1108 (which should be mentioned in all correspondence concerning this draft guide), is "Combining Modal Responses and Spatial Components in Seismic Response Analysis." This draft guide is a proposed Revision 2 of Regulatory Guide 1.92, and it is being revised to improve the guidance to licensees and applicants on methods acceptable to the NRC staff for combining modal responses and spatial components in seismic response analysis in the design and evaluation of nuclear power plant structures, systems, and components important to safety.

This draft guide has not received complete staff approval and does not represent an official NRC staff position.

Comments may be accompanied by relevant information or supporting data. Written comments may be submitted to the Rules and Directives Branch, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555. Copies of comments received may be examined at the NRC Public Document Room, 11555 Rockville Pike, Rockville, MD. Comments will be most helpful if received by October 22, 2001.

You may also provide comments via the NRC's interactive rulemaking web site through the NRC home page (<http://www.nrc.gov>). This site provides the availability to upload comments as

files (any format) if your web browser supports that function. For information about the interactive rulemaking Web site, contact Ms. Carol Gallagher, (301) 415-5905; e-mail CAG@NRC.GOV. For information about the draft guide and the related documents, contact Mr. O.P. Gormley at (301) 415-6793; e-mail OPG@NRC.GOV.

Although a time limit is given for comments on this draft guide, comments and suggestions in connection with items for inclusion in guides currently being developed or improvements in all published guides are encouraged at any time.

Regulatory guides are available for inspection at the NRC's Public Document Room, 11555 Rockville Pike, Rockville, MD; the PDR's mailing address is USNRC PDR, Washington, DC 20555; telephone (301) 415-4737 or (800) 397-4205; fax (301) 415-3548; email PDR@NRC.GOV. Requests for single copies of draft or final guides (which may be reproduced) or for placement on an automatic distribution list for single copies of future draft guides in specific divisions should be made in writing to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section; or by e-mail to DISTRIBUTION@NRC.GOV; or by fax to (301) 415-2289. Telephone requests cannot be accommodated. Regulatory guides are not copyrighted, and Commission approval is not required to reproduce them.

(5 U.S.C. 552(a))

Dated at Rockville, Maryland, this 29th day of August 2001.

For the Nuclear Regulatory Commission.

Michael E. Mayfield,

Director, Division of Engineering Technology, Office of Nuclear Regulatory Research.

[FR Doc. 01-22516 Filed 9-6-01; 8:45 am]

BILLING CODE 7590-01-P

SECURITIES AND EXCHANGE COMMISSION

Submission for OMB Review, Comment Request

Upon Written Request, Copies Available From: Securities and Exchange Commission, Office of Filings and Information Services, Washington, DC 20549.

Extension:

Rules 17Ad-6 and 17Ad-7, SEC File No. 270-151, OMB Control No. 3235-0291.

Notice is hereby given that, pursuant to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 *et seq.*), the Securities and Exchange Commission