

subscription to the Davis-Bacon Online Service (<http://davisbacon.fedworld.gov>) of the National Technical Information Service (NTIS) of the U.S. Department of Commerce at 1-800-363-2068. This subscription offers value-added features such as electronic delivery of modified wage decisions directly to the user's desktop, the ability to access prior wage decisions issued during the year, extensive Help desk Support, etc.

Hard-copy subscriptions may be purchased from: Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402, (202) 512-1800.

When ordering hard-copy subscription(s), be sure to specify the State(s) of interest, since subscriptions may be ordered for any or all of the six separate volumes, arranged by State. Subscriptions include an annual edition (issued in January or February) which includes all current general wage determinations for the States covered by each volume. Throughout the remainder of the year, regular weekly updates will be distributed to subscribers.

Signed at Washington, DC, this 19th day of May 2005.

**John Frank,**

*Acting Chief, Branch of Construction Wage Determinations.*

[FR Doc. 05-10345 Filed 5-26-05; 8:45 am]

**BILLING CODE 4510-27-M**

## NATIONAL ARCHIVES AND RECORDS ADMINISTRATION

### Advisory Committee on the Records of Congress; Meeting

**AGENCY:** National Archives and Records Administration.

**ACTION:** Notice of meeting.

**SUMMARY:** In accordance with the Federal Advisory Committee Act, the National Archives and Records Administration (NARA) announces a meeting of the Advisory Committee on the Records of Congress. The committee advises NARA on the full range of programs, policies, and plans for the Center for Legislative Archives in the Office of Records Services.

**DATES:** June 13, 2005 from 10 a.m. to 11 a.m.

**ADDRESSES:** The U.S. Capitol Building, Room H-137, Washington, DC.

**FOR FURTHER INFORMATION CONTACT:** Richard H. Hunt, Director; Center for Legislative Archives; (202) 501-5350.

**SUPPLEMENTARY INFORMATION:**

## Agenda

Capitol Visitor Center Update on Exhibitory/Construction; Association of Centers for the Study of Congress; Institute on the Teaching of Congress and the Presidency; Web Harvest; Fourth Advisory Committee on the Records of Congress Report; Activities Report of the Center for Legislative Archives; Other current issues and new business.

The meeting is open to the public.

Dated: May 23, 2005.

**Mary Ann Hadyka,**

*Committee Management Officer.*

[FR Doc. 05-10628 Filed 5-26-05; 8:45 am]

**BILLING CODE 7515-01-P**

## NATIONAL SCIENCE FOUNDATION

### Proposal Review Panel for Materials Research; Notice of Meeting

In accordance with the Federal Advisory Committee Act (Pub. L. 92-463 as amended), the National Science Foundation announces the following meeting:

**Name:** Proposal Review Panel for Materials Research (DMR) #1203.

**Dates & Times:** June 26, 2005; 7 p.m.-9 p.m. (Closed). June 27, 2005; 7:45 a.m.-9:30 p.m. (Open 8:15-12:15, 1:15-3:45). June 28, 2005; 8 a.m.-4 p.m. (Closed).

**Place:** Rensselaer Polytechnic Institute, Troy, New York.

**Type of Meeting:** Part Open.

**Contact Person:** Dr. David L. Nelson, Program Director, Solid State Chemistry Program, Division of Materials Research, Room 1065, National Science Foundation, 4201 Wilson Boulevard, Arlington, VA 22230, Telephone (703) 292-4932.

**Agenda:** June 26, 2005—Closed. June 27, 2005—Open for Director's overview of Nanoscale Science and Engineering Center and presentations. June 28, 2005—Closed to review and evaluate progress of Nanoscale Science and Engineering Center.

**Reason for Closing:** The work being reviewed may include information of a proprietary or confidential nature, including technical information; financial data, such as salaries and personal information concerning individuals associated with the proposals. These matters are exempt under 5 U.S.C. 552b(c), (4) and (6) of the Government in the Sunshine Act.

Dated: May 24, 2005.

**Susanne Bolton,**

*Committee Management Officer.*

[FR Doc. 05-10654 Filed 5-26-05; 8:45 am]

**BILLING CODE 7555-01-M**

## NUCLEAR REGULATORY COMMISSION

### Agency Information Collection Activities: Submission for the Office of Management and Budget (OMB) Review; Comment Request

**AGENCY:** U.S. Nuclear Regulatory Commission (NRC).

**ACTION:** Notice of the OMB review of information collection and solicitation of public comment.

**SUMMARY:** The NRC has recently submitted to OMB for review the following proposal for the collection of information under the provisions of the Paperwork Reduction Act of 1995 (44 U.S.C. Chapter 35). The NRC hereby informs potential respondents that an agency may not conduct or sponsor, and that a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number.

1. *Type of submission, new, revision, or extension:* Extension.

2. *The title of the information collection:* Design Information Questionnaire—IAEA—N-71 and associated Forms N-72, N-73, N-74, N-75, N-91, N-92, N-93, N-94.

3. *The form number if applicable:* IAEA Form N-71 and associated Forms N-72, N-73, N-74, N-75, N-91, N-92, N-93, N-94.

4. *How often the collection is required:* Approximately 1 time annually.

5. *Who will be required or asked to report:* Licensees of facilities on the U.S. eligible list who have been notified in writing by the Commission to submit the form.

6. *An estimate of the number of annual responses:* 1.

7. *The estimated number of annual respondents:* 1.

8. *An estimate of the total number of hours needed annually to complete the requirement or request:* 360 reporting hours (360 hours per response).

9. *An indication of whether Section 3507(d), Pub. L. 104-13 applies:* N/A.

10. *Abstract:* Licensees of facilities that appear on the U.S. eligible list, pursuant to the US/IAEA Safeguards Agreement, and who have been notified in writing by the Commission, are required to complete and submit a Design Information Questionnaire, IAEA Form N-71 (and the appropriate associated IAEA Form) or Form N-91, to provide information concerning their installation for use of the International Atomic Energy Agency.

A copy of the final supporting statement may be viewed free of charge

at the NRC Public Document Room, One White Flint North, 11555 Rockville Pike, Room O-1 F21, Rockville, MD 20852. OMB clearance requests are available at the NRC worldwide Web site: <http://www.nrc.gov/public-involve/doc-comment/omb/index.html>. The document will be available on the NRC home page site for 60 days after the signature date of this notice.

Comments and questions should be directed to the OMB reviewer listed below by June 27, 2005. Comments received after this date will be considered if it is practical to do so, but assurance of consideration cannot be given to comments received after this date. John Asalone, Office of Information and Regulatory Affairs (3150-0056), NEOB-10202, Office of Management and Budget, Washington, DC 20503.

Comments can also be e-mailed to [John\\_A.\\_Asalone@omb.eop.gov](mailto:John_A._Asalone@omb.eop.gov) or submitted by telephone at (202) 395-3087.

The NRC Clearance Officer is Brenda Jo. Shelton, 301-415-7233.

Dated at Rockville, Maryland, this 23rd day of May, 2005.

For the Nuclear Regulatory Commission.

**Brenda Jo. Shelton,**

*NRC Clearance Officer, Office of the Chief Information Officer.*

[FR Doc. E5-2689 Filed 5-26-05; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-334 AND 50-412 and License Nos. DPR-66 and NPF-73]

### FirstEnergy Nuclear Operating Company (FENOC) Receipt of Request for Action Under 10 CFR 2.2206

Notice is hereby given that by petition dated April 12, 2005, Mr. David Lochbaum of the Union of Concerned Scientists requested that the Nuclear Regulatory Commission (NRC) take action with regard to Beaver Valley Power Station, Unit Nos. 1 and 2. The petitioner requests that the NRC take enforcement action against FENOC and impose a civil penalty of at least \$55,000.

As the basis for this request, the petitioner states that the licensee's February 9, 2005, license renewal submittal was not complete and accurate in all material respects and that this is a violation of 10 CFR 50.9, paragraph (a) which requires in part, that information provided to the Commission by a licensee shall be complete and accurate in all material respects.

The petition is being treated pursuant to 10 CFR 2.206 of the Commission's regulations. The petition has been referred to the Director of the Office of Nuclear Reactor Regulation. As provided by Section 2.206, appropriate action will be taken on this petition within a reasonable time. Mr. Lochbaum declined to meet with or participate in a telephone conference with the Petition Review Board on this matter stating that all pertinent facts were contained within his petition. Copies of the petition are available for inspection at the Commission's Public Document Room, located at One White Flint North, Public File Area O-1F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible from the Agencywide Documents Access and Management System (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html> (Accession No. ML051100297). Persons who do not have access to ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209 or 301-415-4737, or by e-mail to [pdr@nrc.gov](mailto:pdr@nrc.gov).

For the Nuclear Regulatory Commission.

Dated at Rockville, Maryland this 20th day of May 2005.

**J. E. Dyer,**

*Director, Office of Nuclear Reactor Regulation.*

[FR Doc. E5-2687 Filed 5-26-05; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-266 and 50-301]

### Nuclear Management Company, LLC; Point Beach Nuclear Plant, Units 1 and 2; Environmental Assessment and Finding of No Significant Impact

The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of an exemption from Title 10 of the Code of Federal Regulations (10 CFR) Part 50, Appendix R, Section III.G.1.a for Facility Operating License Nos. DPR-24 and DPR-27, issued to Nuclear Management Company, LLC (NMC), the licensee, for operation of the Point Beach Nuclear Plant (PBNP), Units 1 and 2, located in Manitowoc County, Wisconsin. Therefore, as required by 10 CFR 51.21, the NRC is issuing this environmental assessment and finding of no significant impact.

## Environmental Assessment

### Identification of the Proposed Action

The proposed action would exempt 10 CFR Part 50, Appendix R, Section III.G.1.a as it applies to the PBNP, Unit 1 auxiliary and turbine buildings; and the PBNP, Unit 2 auxiliary and turbine buildings, and the control building. The exemption requested is from the requirement that, "one train of systems necessary to achieve and maintain hot shutdown from either the control room or emergency control station(s) is free of fire damage," as it applies to the PBNP, Unit 1 auxiliary and turbine buildings; the PBNP, Unit 2 auxiliary and turbine buildings, and the control building. Specifically, NMC has asked for a repair consisting of powering a dedicated air compressor from one of two pre-planned 480 volt power sources using pre-staged power cords and connecting the air compressor to nitrogen bottle manifolds on one or both reactor units using pre-staged pneumatic hose with quick connect fittings. The repair would be required no earlier than 8 hours into an event in which instrument air is disabled.

The proposed action is in accordance with the licensee's application dated March 5, 2004, as supplemented by letter dated November 8, 2004.

### The Need for the Proposed Action

Appendix R, Section III.G.1.a of 10 CFR Part 50 requires that, "one train of systems necessary to achieve and maintain hot shutdown conditions from either the control room or emergency control station(s) is free of fire damage." Appendix R, Section III.L.1 of 10 CFR Part 50 requires that an alternative or dedicated shutdown capability shall be able to, among other things, "(c) achieve and maintain hot standby conditions for a pressurized water reactor (PWR)"; and "(d) achieve cold shutdown conditions within 72 hours." NRC Inspection Report 50-266/2003-007; 50-301/2003-007, dated February 4, 2004, documents a Non-Cited Violation of Appendix R, Section III.L.1.c, in that NMC, "failed to ensure, without the need for 'hot standby repairs,' adequate control air to the speed controllers for the charging pumps during a postulated fire requiring an alternative shutdown method." The installed backup nitrogen gas bottle bank (for the charging pump speed controllers) meets the requirements of the regulation, with the exception that it is of limited capacity. This means that the hot shutdown conditions could not be maintained indefinitely while relying only on the installed bottle bank. However, the 8 to 14 hour capacity of the bottle banks is