

§ 15.607 Equipment authorization of Access BPL equipment.

Access BPL equipment shall be subject to Certification as specified in § 15.101.

§ 15.609 Marketing of Access BPL equipment.

The marketing of Access BPL equipment must be directed solely to parties eligible to operate the equipment. Eligible parties consist of AC power line public utilities, Access BPL service providers and associates of Access BPL service providers. The responsible party, as defined in § 2.909 of this chapter, is responsible for ensuring that the equipment is marketed only to eligible parties. Marketing of the equipment in any other manner may be considered grounds for revocation of the grant of certification issued for the equipment.

§ 15.611 General technical requirements.

(a) *Conducted emission limits.* Access BPL is not subject to the conducted emission limits of § 15.107.

(b) *Radiated emission limits—(1) Medium voltage power lines.* (i) Access BPL systems that operate in the frequency range of 1.705 kHz to 30 MHz over medium voltage power lines shall comply with the radiated emission limits for intentional radiators provided in § 15.209.

(ii) Access BPL systems that operate in the frequency range above 30 MHz over medium voltage power lines shall comply with the radiated emission limits provided in § 15.109(b).

(2) *Low voltage power lines.* Access BPL systems that operate over low-voltage power lines, including those that operate over low-voltage lines that are connected to the in-building wiring, shall comply with the radiated emission limits provided in § 15.109(a) and (e).

(c) *Interference Mitigation and Avoidance.* (1) Access BPL systems shall incorporate adaptive interference mitigation techniques to remotely reduce power and adjust operating frequencies, in order to avoid site-specific, local use of the same spectrum by licensed services. These techniques may include adaptive or “notch” filtering, or complete avoidance of fre-

quencies, or bands of frequencies, locally used by licensed radio operations.

(i) For frequencies below 30 MHz, when a notch filter is used to avoid interference to a specific frequency band, the Access BPL system shall be capable of attenuating emissions within that band to a level at least 20 dB below the applicable part 15 limits.

(ii) For frequencies above 30 MHz, when a notch filter is used to avoid interference to a specific frequency band, the Access BPL system shall be capable of attenuating emissions within that band to a level at least 10 dB below the applicable part 15 limits.

(iii) At locations where an Access BPL operator attenuates radiated emissions from its operations in accordance with the above required capabilities, we will not require that operator to take further actions to resolve complaints of harmful interference to mobile operations.

(2) Access BPL systems shall comply with applicable radiated emission limits upon power-up following a fault condition, or during a start-up operation after a shut-off procedure, by the use of a non-volatile memory, or some other method, to immediately restore previous settings with programmed notches and excluded bands, to avoid time delay caused by the need for manual re-programming during which protected services may be vulnerable.

(3) Access BPL systems shall incorporate a remote-controllable shut-down feature to deactivate, from a central location, any unit found to cause harmful interference, if other interference mitigation techniques do not resolve the interference problem.

[70 FR 1374, Jan. 7, 2005, as amended at 71 FR 49379, Aug. 23, 2006]

§ 15.613 Measurement procedures.

Compliance measurements for Access BPL shall be made in accordance with the Guidelines for Access BPL systems specified by the Commission.

§ 15.615 General administrative requirements.

(a) *Access BPL Database.* Entities operating Access BPL systems shall supply to an industry-recognized entity, information on all existing Access BPL systems and all proposed Access BPL