§ 14.21

- (c) Information Pass Through. Equipment used for advanced communications services, including end user equipment, network equipment, and software must pass through cross-manufacturer, nonproprietary, industrystandard codes, translation protocols, formats or other information necessary to provide advanced communications services in an accessible format, if achievable. Signal compression technologies shall not remove information needed for access or shall restore it upon decompression.
- (d) Information, documentation, and training. Manufacturers and service providers must ensure that the information and documentation that they provide to customers is accessible, if achievable. Such information and documentation includes, but is not limited to, user guides, bills, installation guides for end user devices, and product support communications. The requirement to ensure the information is accessible also includes ensuring that individuals with disabilities can access, at no extra cost, call centers and customer support regarding both the product generally and the accessibility features of the product.

§14.21 Performance Objectives.

- (a) Generally. Manufacturers and service providers shall ensure that equipment and services covered by this part are accessible, usable, and compatible as those terms are defined in paragraphs (b) through (d) of this section.
- (b) Accessible. The term accessible shall mean that:
- (1) Input, control, and mechanical functions shall be locatable, identifiable, and operable in accordance with each of the following, assessed independently:
- (i) Operable without vision. Provide at least one mode that does not require user vision.
- (ii) Operable with low vision and limited or no hearing. Provide at least one mode that permits operation by users with visual acuity between 20/70 and 20/200, without relying on audio output.
- (iii) Operable with little or no color perception. Provide at least one mode that does not require user color perception.

- (iv) *Operable without hearing*. Provide at least one mode that does not require user auditory perception.
- (v) Operable with limited manual dexterity. Provide at least one mode that does not require user fine motor control or simultaneous actions.
- (vi) Operable with limited reach and strength. Provide at least one mode that is operable with user limited reach and strength.
- (vii) Operable with a Prosthetic Device. Controls shall be operable without requiring body contact or close body proximity.
- (viii) Operable without time-dependent controls. Provide at least one mode that does not require a response time or allows response time to be by-passed or adjusted by the user over a wide range.
- (ix) *Operable without speech*. Provide at least one mode that does not require user speech.
- (x) Operable with limited cognitive skills. Provide at least one mode that minimizes the cognitive, memory, language, and learning skills required of the user.
- (2) All information necessary to operate and use the product, including but not limited to, text, static or dynamic images, icons, labels, sounds, or incidental operating cues, [shall] comply with each of the following, assessed independently:
- (i) Availability of visual information. Provide visual information through at least one mode in auditory form.
- (ii) Availability of visual information for low vision users. Provide visual information through at least one mode to users with visual acuity between 20/70 and 20/200 without relying on audio.
- (iii) Access to moving text. Provide moving text in at least one static presentation mode at the option of the user.
- (iv) Availability of auditory information. Provide auditory information through at least one mode in visual form and, where appropriate, in tactile form.
- (v) Availability of auditory information for people who are hard of hearing. Provide audio or acoustic information, including any auditory feedback tones that are important for the use of the product, through at least one mode in

enhanced auditory fashion (*i.e.*, increased amplification, increased signal-to-noise ratio, or combination).

- (vi) Prevention of visually-induced seizures. Visual displays and indicators shall minimize visual flicker that might induce seizures in people with photosensitive epilepsy.
- (vii) Availability of audio cutoff. Where a product delivers audio output through an external speaker, provide an industry standard connector for headphones or personal listening devices (e.g., phone-like handset or earcup) which cuts off the speaker(s) when used.
- (viii) Non-interference with hearing technologies. Reduce interference to hearing technologies (including hearing aids, cochlear implants, and assistive listening devices) to the lowest possible level that allows a user to utilize the product.
- (ix) Hearing aid coupling. Where a product delivers output by an audio transducer which is normally held up to the ear, provide a means for effective wireless coupling to hearing aids.
- (c) Usable. The term usable shall mean that individuals with disabilities have access to the full functionality and documentation for the product, including instructions, product information (including accessible feature information), documentation and technical support functionally equivalent to that provided to individuals without disabilities.
- (d) Compatible. The term compatible shall mean compatible with peripheral devices and specialized customer premises equipment, and in compliance with the following provisions, as applicable:
- (1) External electronic access to all information and control mechanisms. Information needed for the operation of products (including output, alerts, icons, on-line help, and documentation) shall be available in a standard electronic text format on a cross-industry standard port and all input to and control of a product shall allow for real time operation by electronic text input into a cross-industry standard external port and in cross-industry standard format. The cross-industry standard port shall not require manipulation of a connector by the user.

- (2) Connection point for external audio processing devices. Products providing auditory output shall provide the auditory signal at a standard signal level through an industry standard connector.
- (3) TTY connectability. Products that provide a function allowing voice communication and which do not themselves provide a TTY functionality shall provide a standard non-acoustic connection point for TTYs. It shall also be possible for the user to easily turn any microphone on and off to allow the user to intermix speech with TTY use.
- (4) TTY signal compatibility. Products, including those providing voice communication functionality, shall support use of all cross-manufacturer non-proprietary standard signals used by TTYs.

Subpart D—Recordkeeping, Consumer Dispute Assistance, and Enforcement

§14.30 Generally.

- (a) The rules in this subpart regarding recordkeeping and enforcement are applicable to all manufacturers and service providers that are subject to the requirements of sections 255, 716, and 718 of the Act and parts 6, 7 and 14 of this chapter.
- (b) The requirements set forth in §14.31 of this subpart shall be effective January 30, 2013.
- (c) The requirements set forth in §§14.32 through 14.37 of this subpart shall be effective on October 8, 2013.

§14.31 Recordkeeping.

- (a) Each manufacturer and service provider subject to section 255, 716, or 718 of the Act, must create and maintain, in the ordinary course of business and for a two year period from the date a product ceases to be manufactured or a service ceases to be offered, records of the efforts taken by such manufacturer or provider to implement sections 255, 716, and 718 with regard to this product or service, as applicable, including:
- (1) Information about the manufacturer's or service provider's efforts to consult with individuals with disabilities;