

## Federal Communications Commission

## § 73.150

$A_{sn}$  and  $B_{sn}$  are the  $n^{\text{th}}$  sine and cosine coefficients of  $C_{sn}$   
 $A_{dn}$  and  $B_{dn}$  are the  $n^{\text{th}}$  sine and cosine coefficients of  $C_{dn}$

[58 FR 66301, Dec. 20, 1993]

### § 73.132 Territorial exclusivity.

No licensee of an AM broadcast station shall have any arrangement with a network organization which prevents or hinders another station serving substantially the same area from broadcasting the network's programs not taken by the former station, or which prevents or hinders another station serving a substantially different area from broadcasting any program of the network organization: *Provided, however,* That this section does not prohibit arrangements under which the station is granted first call within its primary service area upon the network's programs. The term "network organization" means any organization originating program material, with or without commercial messages, and furnishing the same to stations interconnected so as to permit simultaneous broadcast by all or some of them. However, arrangements involving only stations under common ownership, or only the rebroadcast by one station or programming from another with no compensation other than a lump-sum payment by the station rebroadcasting, are not considered arrangements with a network organization. The term "arrangement" means any contract, arrangement or understanding, expressed or implied.

[42 FR 16422, Mar. 28, 1977]

### § 73.150 Directional antenna systems.

(a) For each station employing a directional antenna, all determinations of service provided and interference caused shall be based on the inverse distance fields of the standard radiation pattern for that station. (As applied to nighttime operation the term "standard radiation pattern" shall include the radiation pattern in the horizontal plane, and radiation patterns at angles above this plane.)

(1) Parties submitting directional antenna patterns pursuant to this section and § 73.152 (Modified standard pattern) must submit patterns which are tabulated and plotted in units of millivolts per meter at 1 kilometer.

NOTE: Applications for new stations and for changes (both minor and major) in existing stations must use a standard pattern.

(b) The following data shall be submitted with an application for authority to install a directional antenna:

(1) The standard radiation pattern for the proposed antenna in the horizontal plane, and where pertinent, tabulated values for the azimuthal radiation patterns for angles of elevation up to and including 60 degrees, with a separate section for each increment of 5 degrees.

(i) The standard radiation pattern shall be based on the theoretical radiation pattern. The theoretical radiation pattern shall be calculated in accordance with the following mathematical expression:

$$E(\phi, \theta)_{th} = \left| k \sum_{i=1}^n F_i f_i(\theta) / S_i \cos \theta \cos(\phi_i - \phi) + \psi_i \right| \quad (\text{Eq. 1})$$

where:

$E(\phi, \theta)_{th}$  Represents the theoretical inverse distance fields at one kilometer for the given azimuth and elevation.

$k$  Represents the multiplying constant which determines the basic pattern size. It shall be chosen so that the effective field (RMS) of the theoretical pattern in the horizontal plane shall be no greater than the value computed on the assumption

that nominal station power (see § 73.14) is delivered to the directional array, and that a lumped loss resistance of one ohm exists at the current loop of each element of the array, or at the base of each element of electrical height lower than 0.25 wavelength, and no less than the value required by § 73.189(b)(2) of this part for a station of the class and

§ 73.150

- nominal power for which the pattern is designed.
- $n$  Represents the number of elements (towers) in the directional array.
- $i$  Represents the  $i^{\text{th}}$  element in the array.
- $F_i$  Represents the field ratio of the  $i^{\text{th}}$  element in the array.
- $\theta$  Represents the vertical elevation angle measured from the horizontal plane.
- $f_i(\theta)$  represents the vertical plane radiation characteristic of the  $i^{\text{th}}$  antenna. This value depends on the tower height, as well as whether the tower is top-loaded or sectionalized. The various formulas for computing  $f_i(\theta)$  are given in § 73.160.
- $S_i$  Represents the electrical spacing of the  $i^{\text{th}}$  tower from the reference point.
- $\phi_i$  Represents the orientation (with respect to true north) of the  $i^{\text{th}}$  tower.
- $\phi$  Represents the azimuth (with respect to true north).
- $\psi_i$  Represents the electrical phase angle of the current in the  $i^{\text{th}}$  tower.

The standard radiation pattern shall be constructed in accordance with the following mathematical expression:

$$E(\phi, \theta)_{\text{std}} = 1.05 \sqrt{[E(\phi, \theta)_{\text{th}}]^2 + Q^2}$$

(Eq. 2)

where:

$E(\phi, \theta)_{\text{std}}$  represents the inverse distance fields at one kilometer which are produced by the directional antenna in the horizontal and vertical planes.  $E(\phi, \theta)_{\text{th}}$  represents the theoretical inverse distance fields at one kilometer as computed in accordance with Eq. 1, above.

$Q$  is the greater of the following two quantities:  $0.025g(\theta) E_{\text{rss}}$  or  $10.0g(\theta) \sqrt{P_{\text{kw}}}$

where:

$g(\theta)$  is the vertical plane distribution factor,  $f(\theta)$ , for the shortest element in the array (see Eq. 2, above; also see § 73.190, Figure 5). If the shortest element has an electrical height in excess of 0.5 wavelength,  $g(\theta)$  shall be computed as follows:

$$g(\theta) = \frac{\sqrt{\{f(\theta)\}^2 + 0.0625}}{1.030776}$$

$E_{\text{rss}}$  is the root sum square of the amplitudes of the inverse fields of the elements of the array in the horizontal plane, as used in the expression for  $E(\phi, \theta)_{\text{th}}$  (see Eq. 1, above), and is computed as follows:

$$E_{\text{rss}} = k \sqrt{\sum_{i=1}^n F_i^2}$$

47 CFR Ch. I (10–1–16 Edition)

$P_{\text{kw}}$  is the nominal station power expressed in kilowatts, see § 73.14. If the nominal power is less than one kilowatt,  $P_{\text{kw}} = 1$ .

(ii) Where the orthogonal addition of the factor  $Q$  to  $E(\phi, \theta)_{\text{th}}$  results in a standard pattern whose minimum fields are lower than those found necessary or desirable, these fields may be increased by appropriate adjustment of the parameters of  $E(\phi, \theta)_{\text{th}}$ .

(2) All patterns shall be computed for integral multiples of five degrees, beginning with zero degrees representing true north, and, shall be plotted to the largest scale possible on unglazed letter-size paper (main engraving approximately  $7' \times 10'$ ) using only scale divisions and subdivisions of 1, 2, 2.5, or 5 times  $10^{\text{nth}}$ . The horizontal plane pattern shall be plotted on polar coordinate paper, with the zero degree point corresponding to true north. Patterns for elevation angles above the horizontal plane may be plotted in polar or rectangular coordinates, with the pattern for each angle of elevation on a separate page. Rectangular plots shall begin and end at true north, with all azimuths labelled in increments of not less than 20 degrees. If a rectangular plot is used, the ordinate showing the scale for radiation may be logarithmic. Such patterns for elevation angles above the horizontal plane need be submitted only upon specific request by Commission staff. Minor lobe and null detail occurring between successive patterns for specific angles of elevation need not be submitted. Values of field strength on any pattern less than ten percent of the maximum field strength plotted on that pattern shall be shown on an enlarged scale. Rectangular plots with a logarithmic ordinate need not utilize an expanded scale unless necessary to show clearly the minor lobe and null detail.

(3) The effective (RMS) field strength in the horizontal plane of  $E(\phi, \theta)_{\text{std}}$ ,  $E(\phi, \theta)_{\text{th}}$  and the root-sum-square (RSS) value of the inverse distance fields of the array elements at 1 kilometer, derived from the equation for  $E(\phi, \theta)_{\text{th}}$ . These values shall be tabulated on the page on which the horizontal plane pattern is plotted, which shall be specifically labelled as the Standard Horizontal Plane Pattern.

(4) Physical description of the array, showing:

- (i) Number of elements.
- (ii) Type of each element (*i.e.*, guyed or self-supporting, uniform cross section or tapered (specifying base dimensions), grounded or insulated, etc.)
- (iii) Details of top loading, or sectionalizing, if any.
- (iv) Height of radiating portion of each element in feet (height above base insulator, or base, if grounded).
- (v) Overall height of each element above ground.
- (vi) Sketch of antenna site, indicating its dimensions, the location of the antenna elements, thereon, their spacing from each other, and their orientation with respect to each other and to true north, the number and length of the radials in the ground system about each element, the dimensions of ground screens, if any, and bonding between towers and between radial systems.

(5) Electrical description of the array, showing:

- (i) Relative amplitudes of the fields of the array elements.
- (ii) Relative time phasing of the fields of the array elements in degrees leading [ + ] or lagging [ - ].
- (iii) Space phasing between elements in degrees.
- (iv) Where waiver of the content of this section is requested or upon request of the Commission staff, all assumptions made and the basis therefor, particularly with respect to the electrical height of the elements, current distribution along elements, efficiency of each element, and ground conductivity.

(v) Where waiver of the content of this section is requested, or upon request of the Commission staff, those formulas used for computing  $E(\phi, \theta)_{th}$  and  $E(\phi, \theta)_{std}$ . Complete tabulation of final computed data used in plotting patterns, including data for the determination of the RMS value of the pattern, and the RSS field of the array.

(6) The values used in specifying the parameters which describe the array must be specified to no greater precision than can be achieved with available monitoring equipment. Use of greater precision raises a rebuttable presumption of instability of the array. Following are acceptable values of pre-

cision; greater precision may be used only upon showing that the monitoring equipment to be installed gives accurate readings with the specified precision.

- (i) Field Ratio: 3 significant figures.
- (ii) Phasing: to the nearest 0.1 degree.
- (iii) Orientation (with respect to a common point in the array, or with respect to another tower): to the nearest 0.1 degree.
- (iv) Spacing (with respect to a common point in the array, or with respect to another tower): to the nearest 0.1 degree.
- (v) Electrical Height (for all parameters listed in Section 73.160): to the nearest 0.1 degree.

(vi) Theoretical RMS (to determine pattern size): 4 significant figures.

(vii) Additional requirements relating to modified standard patterns appear in § 73.152(c)(3) and (c)(4).

(7) Any additional information required by the application form.

(c) Sample calculations for the theoretical and standard radiation follow. Assume a five kilowatt (nominal power) station with a theoretical RMS of 685 mV/m at one kilometer. Assume that it is an in-line array consisting of three towers. Assume the following parameters for the towers:

Tower	Field ratio	Relative phasing	Relative spacing	Relative orientation
1 .....	1.0	-128.5	0.0	0.0
2 .....	1.89	0.0	110.0	285.0
3 .....	1.0	128.5	220.0	285.0

Assume that tower 1 is a typical tower with an electrical height of 120 degrees. Assume that tower 2 is top-loaded in accordance with the method described in § 73.160(b)(2) where A is 120 electrical degrees and B is 20 electrical degrees. Assume that tower 3 is sectionalized in accordance with the method described in § 73.160(b)(3) where A is 120 electrical degrees, B is 20 electrical degrees, C is 220 electrical degrees, and D is 15 electrical degrees.

The multiplying constant will be 323.6.

Following is a tabulation of part of the theoretical pattern:

## § 73.151

Azimuth	0	30	60	Vertical angle
0 .....	15.98	62.49	68.20	
105 .....	1225.30	819.79	234.54	
235 .....	0.43	18.46	34.56	
247 .....	82.62	51.52	26.38	

If we further assume that the station has a standard pattern, we find that  $Q$ , for  $\theta = 0$ , is 22.36.

Following is a tabulation of part of the standard pattern:

Azimuth	0	30	60	Vertical angle
0 .....	28.86	68.05	72.06	
105 .....	1286.78	860.97	246.41	
235 .....	23.48	26.50	37.18	
247 .....	89.87	57.03	28.87	

The RMS of the standard pattern in the horizontal plane is 719.63 mV/m at one kilometer.

[36 FR 919, Jan. 20, 1971, as amended at 37 FR 529, Jan. 13, 1972; 41 FR 24134, June 15, 1976; 46 FR 11991, Feb. 12, 1981; 48 FR 24384, June 1, 1983; 51 FR 2707, Jan. 21, 1986; 52 FR 36877, Oct. 1, 1987; 56 FR 64861, Dec. 12, 1991; 57 FR 43290, Sept. 18, 1992]

## § 73.151 Field strength measurements to establish performance of directional antennas.

The performance of a directional antenna may be verified either by field strength measurement or by computer modeling and sampling system verification.

(a) In addition to the information required by the license application form, the following showing must be submitted to establish, for each mode of directional operation, that the effective measured field strength (RMS) at 1 kilometer (km) is not less than 85 percent of the effective measured field strength (RMS) specified for the standard radiation pattern, or less than that specified in § 73.189(b) for the class of station involved, whichever is the higher value, and that the measured field strength at 1 km in any direction does not exceed the field shown in that direction on the standard radiation pattern for that mode of directional operation:

(1) A tabulation of inverse field strengths in the horizontal plane at 1 km, as determined from field strength measurements taken and analyzed in accordance with § 73.186, and a state-

## 47 CFR Ch. I (10–1–16 Edition)

ment of the effective measured field strength (RMS). Measurements shall be made in the following directions:

(i) Those specified in the instrument of authorization.

(ii) In major lobes. Generally, one radial is sufficient to establish a major lobe; however, additional radials may be required.

(iii) Along additional radials to establish the shape of the pattern. In the case of a relatively simple directional antenna pattern, a total of six radials is sufficient. If two radials would be more than 90° apart, then an additional radial must be specified within that arc. When more complicated patterns are involved, that is, patterns having several or sharp lobes or nulls, measurements shall be taken along as many as 12 radials to definitely establish the pattern(s). Pattern symmetry may be assumed for complex patterns which might otherwise require measurements on more than 12 radials.

(2) A tabulation of:

(i) The phase difference of the current in each element with respect to the reference element, and whether the current leads ( + ) or lags ( - ) the current in the reference element, as indicated by the station's antenna monitor.

(ii) The ratio of the amplitude of the radio frequency current in each element to the current in the reference element, as indicated on the station's antenna monitor.

(3) A monitoring point shall be established on each radial for which the construction permit specifies a limit. The following information shall be supplied for each monitoring point:

(i) Measured field strength.

(ii) An accurate and detailed description of each monitoring point. The description may include, but shall not be limited to, geographic coordinates determined with a Global Positioning System receiver.

(iii) Clear photographs taken with the field strength meter in its measuring position and with the camera so located that its field of view takes in as many pertinent landmarks as possible.

(b) For stations authorized to operate with simple directional antenna systems (e.g., two towers) in the 1605–1705