Federal Communications Commission

(3) A description of the device, including the operating frequency, RF power output, and antenna; and,

(4) A statement that the device complies with the technical provisions of this part.

[54 FR 17714, Apr. 25, 1989; 54 FR 32340, Aug. 7, 1989; 80 FR 53750, Sept. 8, 2015]

§15.240 Operation in the band 433.5– 434.5 MHz.

(a) Operation under the provisions of this section is restricted to devices that use radio frequency energy to identify the contents of commercial shipping containers. Operations must be limited to commercial and industrial areas such as ports, rail terminals and warehouses. Two-way operation is permitted to interrogate and to load data into devices. Devices operated pursuant to the provisions of this section shall not be used for voice communications.

(b) The field strength of any emissions radiated within the specified frequency band shall not exceed 11.000 microvolts per meter measured at a distance of 3 meters. The emission limit in this paragraph is based on measurement instrumentation employing an average detector. The peak level of any emissions within the specified frequency band shall not exceed 55,000 microvolts per meter measured at a distance of 3 meters. Additionally, devices authorized under these provisions shall be provided with a means for automatically limiting operation so that the duration of each transmission shall not be greater than 60 seconds and be only permitted to reinitiate an interrogation in the case of a transmission error. Absent such a transmission error, the silent period between transmissions shall not be less than 10 seconds.

(c) The field strength of emissions radiated on any frequency outside of the specified band shall not exceed the general radiated emission limits in §15.209.

(d) In the case of radio frequency powered tags designed to operate with a device authorized under this section, the tag may be approved with the device or be considered as a separate device subject to its own authorization. Powered tags approved with a device under a single application shall be labeled with the same identification number as the device.

(e) To prevent interference to Federal Government radar systems, operation under the provisions of this section is not permitted within 40 kilometers of the following locations:

DoD Radar Site	Latitude	Longitude
Beale Air Force Base	39°08′10″ N	121°21′04″ W
Cape Cod Air Force Station	41°45′07″ N	070°32′17″ W
Clear Air Force Station	64°55′16″ N	143°05′02″ W
Cavalier Air Force Station	48°43′12″ N	097°54′00″ W
Eglin Air Force Base	30°43′12″ N	086°12′36″ W

(f) As a condition of the grant, the grantee of an equipment authorization for a device operating under the provisions of this section shall provide information to the user concerning compliance with the operational restrictions in paragraphs (a) and (e) of this section. As a further condition, the grantee shall provide information on the locations where the devices are installed to the FCC Office of Engineering and Technology, which shall provide this information to the Federal Government through the National Telecommunications and Information Administration. The user of the device shall be responsible for submitting updated information in the event the operating location or other information changes after the initial registration. The grantee shall notify the user of this requirement. The information provided by the grantee or user to the Commission shall include the name, address, telephone number and e-mail address of the user, the address and geographic coordinates of the operating location, and the FCC identification number of the device. The material shall be submitted to the following address:

Experimental Licensing Branch, OET, Federal Communications Commission, 445 12th Street, SW., Washington, DC 20554, ATTN: RFID Registration.

[69 FR 29464, May 24, 2004]

§15.241 Operation in the band 174–216 MHz.

(a) Operation under the provisions of this section is restricted to biomedical telemetry devices.

(b) Emissions from the device shall be confined within a 200 kHz band

47 CFR Ch. I (10–1–20 Edition)

which shall lie wholly within the frequency range of 174–216 MHz.

(c) The field strength of any emissions radiated within the specified 200 kHz band shall not exceed 1500 microvolts/meter at 3 meters. The field strength of emissions radiated on any frequency outside of the specified 200 kHz band shall not exceed 150 microvolts/meter at 3 meters. The emission limits in this paragraph are based on measurement instrumentation employing an average detector. The provisions in \$15.35 for limiting peak emissions apply.

§15.242 Operation in the bands 174– 216 MHz and 470–668 MHz.

(a) The marketing and operation of intentional radiators under the provisions of this section is restricted to biomedical telemetry devices employed solely on the premises of health care facilities.

(1) A health care facility includes hospitals and other establishments that offer services, facilities, and beds for use beyond 24 hours in rendering medical treatment and institutions and organizations regularly engaged in providing medical services through clinics, public health facilities, and similar establishments, including governmental entities and agencies for their own medical activities.

(2) This authority to operate does not extend to mobile vehicles, such as ambulances, even if those vehicles are associated with a health care facility.

(b) The fundamental emissions from a biomedical telemetry device operating under the provisions of this section shall be contained within a single television broadcast channel, as defined in part 73 of this chapter, under all conditions of operation and shall lie wholly within the frequency ranges of 174-216 MHz and 470-668 MHz.

(c) The field strength of the fundamental emissions shall not exceed 200 mV/m, as measured at a distance of 3 meters using a quasi-peak detector. Manufacturers should note that a quasi-peak detector function indicates field strength per 120 kHz of bandwidth ± 20 kHz. Accordingly, the total signal level over the band of operation may be higher than 200 mV/m. The field strength of emissions radiated on any frequency outside of the television broadcast channel within which the fundamental is contained shall not exceed the general limits in §15.209.

(d) The user and the installer of a biomedical telemetry device operating within the frequency range 174-216 MHz, 470-608 MHz or 614-668 MHz shall ensure that the following minimum separation distances are maintained between the biomedical telemetry device and the authorized radio services operating on the same frequencies:

(1) At least 10.3 km outside of the Grade B field strength contour (56 dBuV/m) of a TV broadcast station or an associated TV booster station operating within the band 174–216 MHz.

(2) At least 5.5 km outside of the Grade B field strength contour (64 dBuV/m) of a TV broadcast station or an associated TV booster station operating within the bands 470-608 MHz or 614-668 MHz.

(3) At least 5.1 km outside of the 68 dBuV/m field strength contour of a low power TV or a TV translator station operating within the band 174–216 MHz.

(4) At least 3.1 km outside of the 74 dBuV/m field strength contour of a low power TV or a TV translator station operating within the bands 470–608 MHz or 614–668 MHz.

(5) Whatever distance is necessary to protect other authorized users within these bands.

(e) The user and the installer of a biomedical telemetry device operating within the frequency range 608-614 MHz and that will be located within 32 km of the very long baseline array (VLBA) stations or within 80 km of any of the other radio astronomy observatories noted in footnote US385 of Section 2.106 of this chapter must coordinate with, and obtain the written concurrence of, the director of the affected radio astronomy observatory before the equipment can be installed or operated. The National Science Foundation point of contact for coordination is: Spectrum Manager, Division of Astronomical Sciences, NSF Room 1045, 4201 Wilson Blvd., Arlington, VA 22230; tel: (703) 306-1823.

(f) Biomedical telemetry devices must not cause harmful interference to licensed TV broadcast stations or to other authorized radio services, such as

§ 15.242